

JHARKHAND STATE CRICKET ASSOCIATION

INTERNATIONAL STADIUM COMPLEX,
H.E.C. CAMPUS, DHURWA, RANCHI- 834004

December 6, 2021

Name of work:- Renovation including interior works of Office building of Jharkhand State Cricket Association in the premises of Keenan Stadium Jamshedpur.

REPLIES OF QUERIES RAISED BY BIDDERS

S. No.	Queries by BIDDERS	REPLY OF JSCA
1	Dry wall partition section drawing is required	There will be 2 rows of vertical sections (70x70x2mm). GI Section indicate in the item is to be replaced with two rows of MS sections with one coat of primer and finish coat painting.
2	Otic partition - As the nos is less, is any equivalent make you suggest	Replaced Dorma ALEXA 45 mm System - with sliding doors - Anodised EV1
3.	Item No - 29 (a) & (b)	Deleted
4	SI no. 35 - Detail description/ base rate of texture paint	OIKUS pant for Internal texture paint base price shall be Rs. 1000/- per Ltr.
5	SI no 38, 49, 55 (b) - Drawing is required	Description is self-explanatory
6	SI no 43, 44, 53, 56(a) 56 (b), 57,63 - Base price?	All floor and wall tiles ,excepting soluble salts shall be 600x600 (Base price is 850 per sqm) are of Best/first class quality from reputed manufacturers like Kajaria,/ Orient Bell/
7	SI no 102 &137 - Detail model no and make of light fittings	Corrigendum/ Addendum to be referred. Further Unless otherwise stated all Electrical fittings are of Philips make
8	SI no 51 What is the base price of veneer?	Rs 250 per sft
9	SI no 63 - Please share the detailed drawing and base price of the stone	Description of items for SI no - 63 shall be replaced as follows. Providing and fixing cladding using 5mm thick exterior grade porcelain tiles pasted using approved laticrete adhesive and filling joints with structural silicon sealant include cost to the scrapping the existing paint correcting undulations in the existing surface to true line and level all complete as per direction of Engineer-in-charge.
10	Make for Item no - 57	Keramos / SHAPZU having base price Rs. 3,000/- Sq mtr
11	SI no. 69 & 70 - Depth of storage ?	500mm & 600 mm respectively (approx)
12	SI no. 109 - Instead of PHILIPS, can we consider AHUJA/BOSCH?	JVL / BOSCH can be considered
13	SI.no 111 - Instead of PHILIPS, can we consider SONY?	Approved make shall be SONY
14	Make of Stone for item no - 42 & 58	NITCO (base price Rs. 3,500/- Sq mtr)
15	Item no. 72	One coat of luster paint need not be considered